

SUMMARY OF RESULTS

The equipment complies with the requirements according to the following standards. Summary of all tests are given in table 0-1.

Emission (IEC 61800-3:2004)	
Standard	Result
CISPR 11:2009+AM 2010 Conducted emission on AC lines (150 kHz-30 MHz)	Pass
CISPR 11:2009+AM 2010 Radiated emission (30 MHz-1GHz)	Pass

Table 0-1 (A): Summary of public low voltage limitation test results

Immunity (IEC 61800-3:2004)	
Standard	Result
IEC 61000-4-2:2008 Immunity to electrostatic discharge	Pass
IEC 61000-4-3:2010 Immunity to radiated electromagnetic fields	Pass
IEC 61000-4-4:2012 Immunity to electrical fast transient/burst	Pass
IEC 61000-4-5:2014 Immunity to surge	Pass
IEC 61000-4-6:2013 Immunity to conducted disturbances induced by radio frequency fields	Pass

Table 0-1 (B): Summary of immunity test results

Parand Industrial Estate (laboratory)

Block D.44, Golgasht St. Golzar Ave. Fanavari Blvd.
 Iran
 Tel: +98 2156418864-5
 Fax: +98 2156418892

Tehran (office)

No.3 Roodsar Ave. South Aban St. Karimkhan Blvd.
 Iran
 Tel: +98 2188925950
 Fax: +98 2188937658

National Accreditation Center of Iran
 ISO 17025
 NASI/LAB/183

LQF96-00