

SUMMARY OF RESULTS

The equipment complies with the requirements according to the following standards. Summary of all tests are given in table 0-1.

Emission (IEC 61800-3:2004)	
Standard	Result
CISPR 11:2009+AM 2010 Conducted emission on AC lines (150 kHz-30 MHz)	Pass
CISPR 11:2009+AM 2010 Radiated emission (30 MHz-1GHz)	Pass

Table 0-1 (A): Summary of public low voltage limitation test results

Immunity (IEC 61800-3:2004)	
Standard	Result
IEC 61000-4-2:2008 Immunity to electrostatic discharge	Pass
IEC 61000-4-3:2010 Immunity to radiated electromagnetic fields	Pass
IEC 61000-4-4:2012 Immunity to electrical fast transient/burst	Pass
IEC 61000-4-5:2014 Immunity to surge	Pass
IEC 61000-4-6:2013 Immunity to conducted disturbances induced by radio frequency fields	Pass

Table 0-1 (B): Summary of immunity test results